

# EC Type-Examination Certificate



**Reg.-No.: 01/205/5168.01/16**

**Product tested** Safety Relay Combination **Certificate holder** COMITRONIC-BTI  
ZI Nord des richardets  
34 Allée du closeau  
93160 Noisy le Grand  
France

**Type designation** AWAX26XXL,  
AWAX26XXLP,  
AWAX27XXL

**Codes and standards** EN ISO 13849-1:2015 EN 50178:1997  
EN 62061:2005 + AC:2010 + IEC 61508 Parts 1-7:2010  
A1:2013 + A2:2015  
EN 60947-5-1:2004 + AC:2005 +  
A1:2009

**Intended application** The safety relay combinations comply with the requirements of the relevant standards (Cat. 4 / PL e acc. to EN ISO 13849-1, SIL CL 3 acc. to EN 62061 / IEC 61508) and can be used in applications up to Cat. 4 / PL e and SIL 3.

**Specific requirements** The instructions of the associated Installation and Operating Manual shall be considered.


It is confirmed, that the product under test complies with the requirements for machines defined in Annex I of the EC Directive 2006/42/EC.

Valid until 2021-11-17

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/EL 224.02/16 dated 2016-11-17.

This certificate is valid only for products which are identical with the product tested. It becomes invalid at any change of the codes and standards forming the basis of testing for the intended application.

Berlin, 2016-11-17



Notified Body for Machinery, NB 0035

Dipl.-Ing. Eberhard Frejno

www.fs-products.com  
www.tuv.com

 **TÜVRheinland®**  
Precisely Right.